



TABLE 6C-1: PRESCRIPTIVE REQUIREMENTS FOR SMALL ADDITIONS (600 Sq. Ft. and Less), RENOVATIONS TO EXISTING BUILDINGS AND SITE-INSTALLED COMPONENTS OF MANUFACTURED HOMES

COMPONENT		MINIMUM INSULATION	INSULATION INSTALLED	EQUIPMENT		MINIMUM EFFICIENCY	INSTALLED EFFICIENCY
WALLS	Concrete Block	R-7	_____	COOLING	Central A/C - Split - Single Pkg. Room unit or PTAC	SEER = 13.0*	SEER = _____
	Frame, 2' x 4'	R-11	_____			SEER = 13.0*	SEER = _____
CEILINGS	Under Attic	R-30	_____	SPACE HEATING	Electric Resistance Heat pump - Split - Single Pkg. Room unit or PTHP	ANY	HSPF = _____
	Single Assembly; Enclosed	R-19	_____			HSPF = 7.7*	HSPF = _____
	Frame	R-13	_____			HSPF = 7.7*	HSPF/COP = _____
	Metal Pans	R-10	_____			COP = 2.7*	
FLOORS	Slab-on-grade	No Minimum	_____	HOT WATER	Gas, natural or propane Fuel Oil	AFUE = .78	AFUE = _____
	Raised Wood	R-19	_____			AFUE = .78	AFUE = _____
DUCT	Raised Concrete	R-7	_____	Electric Resistance	Gas; natural or LP Fuel Oil	EF = .92	EF = _____
	Common, Frame	R-11	_____			EF = .54	EF = _____
DUCT	In unconditioned space	R-6	_____				
	In conditioned space	No minimum	_____				

TABLE 6C-2: PRESCRIPTIVE REQUIREMENTS FOR GLASS AREAS IN ADDITIONS ONLY

\* See Table 13-607.1.ABC.3.2 and 13-608.1.ABC.3.2

Maximum percentage glass to floor area allowed is selected by type, overhang length, and solar heat gain coefficient. Maximum % = _____ Installed % = _____								
GLASS TYPE, OVERHANG, AND SOLAR HEAT GAIN COEFFICIENT REQUIRED FOR GLASS PERCENTAGE ALLOWED								
UP TO 20%		UP TO 30%		UP TO 40%		UP TO 50%		
Single	Double	Single	Double	Single	Double	Single	Double	
OH-SHGC	OH-SHGC	OH-SHGC	OH-SHGC	OH-SHGC	OH-SHGC	OH-SHGC	OH-SHGC	
1' - .87	0' - .78	2' - .87	1' - .78	NOT ALLOWED	2' - .78	NOT ALLOWED	3' - .78	
0' - .75		1' - .75	0' - .61		1' - .61		2' - .61	
		0' - .57			0' - .44		1' - .44	
							0' - .35	
Get certified SHGC from the manufacturer or use defaults: Single clear SHGC = .75, double clear SHGC = .66, and single tint SHGC = .64								

TABLE 6C-3 MINIMUM REQUIREMENTS FOR ALL PACKAGES

COMPONENTS	SECTION	REQUIREMENTS	CHECK
Exterior Joints & Cracks	606.1	To be caulked, gasketed, weather-stripped or otherwise sealed.	
Exterior Windows & Doors	606.1	Max. 0.3 cfm/sq.ft. window area; .5 cfm/sq.ft. door area.	
Sole & Top Plates	606.1	Sole plates and penetrations through top plates of exterior walls must be sealed.	
Recessed Lighting	606.1	Type IC rated with no penetrations (two alternatives allowed).	
Multistory Houses	606.1	Air barrier on perimeter of floor cavity between floors.	
Exhaust Fans	606.1	Exhaust fans vented to unconditioned space shall have dampers, except for combustion devices with integral exhaust ductwork.	
Combustion Heating	606.1	Combustion space and water heating systems must be provided with outside combustion air, except for direct vent appliances.	
Water Heaters	612.1	Comply with efficiency requirements in Table 612.1.ABC.3.2. Switch or clearly marked circuit breaker electric or cutoff (gas) must be provided. External or built-in heat trap required for vertical pipe risers.	
Swimming Pools & Spas	612.1	Spas & heated pools must have covers (except solar heated). Noncommercial pools must have a pump timer. Gas spa & pool heaters must have minimum thermal efficiency of 78%.	
Hot Water Pipes	612.1	Insulation is required for hot water circulating systems (including heat recovery units).	
Shower Heads	612.1	Water flow must be restricted to no more than 2.5 gallons per minute at 80 psig.	
HVAC Duct Construction, Insulation & Installation	610.1	All ducts, fittings, mechanical equipment and plenum chambers shall be mechanically attached, sealed, insulated and installed in accordance with the criteria of Section 610.1. Ducts in attics must be insulated to a minimum of R-6.	
HVAC Controls	607.1	Separate readily accessible manual or automatic thermostat for each system.	

GENERAL DIRECTIONS:

- On Table 6C-1 indicate the R-value of the insulation being added to each component and the efficiency levels of the equipment being installed. All R-values and efficiencies installed must meet or exceed the minimum values listed. Components and equipment neither being added nor renovated may be left blank.
- ADDITIONS ONLY. Determine the percentage of new glass to conditioned floor area in the addition as follows. Total the areas of all glass windows, sliding glass doors and glass door panels. Double the area of all nonvertical roof glass and add it to the previous total. When glass in existing exterior walls is being removed or enclosed by the addition, an amount equal to the total area of this glass may be subtracted from the total glass area. Divide the adjusted glass area total by the conditioned floor area of the addition. Multiply by 100 to get the percent. Find the largest glass percentage under which your calculated percentage falls on Table 6C-2. Prescriptives are given by the type of glass (single or double pane) and the overhang (OH) paired with a solar heat gain coefficient (SHGC). For a given glass type and overhang, the minimum solar heat gain coefficient allowed is specified. Actual glass windows and doors previously in the exterior walls of the house and being reinstalled in the addition do not have to comply with the overhang and solar heat gain coefficient requirements on Table 6C-2. All new glass in the addition must meet the requirement for one of the options in the glass percentage category you indicated. The overhang (OH) distance is measured perpendicularly from the face of the glass to a point directly under the outermost edge of the overhang.
- RENOVATIONS ONLY. Replacement glass needs to meet the following requirements. Any glass type and solar heat gain coefficient may be used for glass areas which are under at least a 2-foot overhang and whose lowest edge does not extend further than 8 feet from the overhang. Glass areas being renovated that do not meet this criteria must be either single-pane tinted, double-pane clear or double-pane tinted.
- BUILDING SYSTEMS. Comply when new system is installed for system installed.
- Complete the information requested on the top half of page 1.
- Read "Minimum Requirements for Small Additions and Renovations," Table 6C-3, and check all applicable items.
- Read, sign and date the "Owner/Agent" certification statement on page 1.